

City of Waterville, Maine  
**Addendum #1**  
**For Renovation and Expansion**  
**Of**  
**MAINTENANCE & OPERATIONS BUILDING**  
**Department of Public Works and Parks & Recreation**  
Prepared By:  
**Mark L. Turner, Director of Public Works**  
**Robert Gilchrist, Project Manager/Engineer**



**NOTICE TO BID PARTICIPANTS**  
**Renovation and Expansion Project**  
**MAINTENANCE & OPERATIONS BUILDING**

**Addendum #1 February 2, 2010**

1. Bid date is extended 1 week to : Tuesday February 16, 2010 @ 9:00am
2. Owner provided services to include all demolition and removals.
3. Exterior wainscoting treatment shall be limited to the front and two sides of the building .
4. Second floor ( mezzanine) shall be accessed by a second set of stairs and shall have a full height fire wall. Garage side shall have FRP panels and an 8 foot roll up door to access the second level. (see attach revised floor plan)
5. Washbay: Owner to provide and install oil/sand interceptor on owner provided sanitary sewer connection.
6. Washbay drain shall have a sump serviceable by a 50” skid steer bucket.
7. Washbay shall be heated by a modine type coil heated off the boiler.
8. Washbay shall have two 12’ wide by 14’ high roll up doors, minimum washbay height to be 16 feet.
9. Acknowledge receipt of this addendum in your proposal.

END of ADDENDUM