

City of Waterville, Maine  
**Addendum #2**  
**For Renovation and Expansion**  
**Of**  
**MAINTENANCE & OPERATIONS BUILDING**  
**Department of Public Works and Parks & Recreation**  
Prepared By:  
**Mark L. Turner, Director of Public Works**  
**Robert Gilchrist, Project Manager/Engineer**



**NOTICE TO BID PARTICIPANTS**  
**Renovation and Expansion Project**  
**MAINTENANCE & OPERATIONS BUILDING**

**Addendum #2 February 8, 2010**

1. Exhibit A Section 1, E 3 Builders Risk, shall not be required on the existing building.
2. Section 5 – Metals, D should read : 125 psf floor loading
3. Section 7 – Finishes should read : 26 gauge by Metal Sales Manufacturing ....
4. Section 10 – Wash Bay Construction A, 1 Roof design will be less than 30 deg. Pitch given the height of existing building and clearance requirements.
5. Wash bay: Owner will reuse our existing pressure washer, hose reel, wand etc. in the new building.
6. Acknowledge receipt of this addendum in proposal.

Other clarifications: we would accept 2- 4' by 6'8" doors in lieu of roll up for mezzanine.

Sanitary sewer will be installed by the owner along the east wall of the building providing options for the interior plumbing.

Bidders shall assume a 12" wide CMU footing on the existing building.

END of ADDENDUM